

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240550

Address: 3734 SW KNOXVILLE CT, LEES SUMMIT, MO 640823736 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Tuesday, July 16, 2024

Partial Correction:

1	Miscellaneous Correction	3734 -Missing blow off tube on water heater -It appears that TR outlets were not used throughout -Fire blocking at bottom of chase in garage 3736 -It appears that TR outlets were not used throughout -First stair riser to upstairs over 7 3/4" -Patio sliding door lock and secondary not operating correctly -Fire blocking at bottom of chase in garage
---	--------------------------	--

Comments: