


5719 LAWTON LOOP E. DR. #212
INDIANAPOLIS, IN 46216
O :: 317.288.0681
F :: 317.288.0753



CERTIFICATION



PROJECT INFORMATION

X CORNER OF
NE TUDOR RD & MAIN ST
LEE'S SUMMIT, MO 64086

ISSUE DATES

PERMIT SET 04.26.22

220019

FA.00



FIRE ALARM SYMBOL LEGEND	
 -FIRE ALARM CONTROL PANEL	 -HEAT DETECTOR
 -NAC PANEL	 -WATER FLOW MONITOR MODULE
 -CEILING MOUNT HORN-STROBE	 -TAMPER MONITOR MODULE
 -CEILING MOUNT STROBE	 - RETURN DUCT DETECTOR
 -PHOTO ELECTRIC SMOKE DETECTOR.	 -RELAY
 -PULL-STATION	 -END OF LINE RESISTOR
 -Remote Annunciator	 - MONITOR MODULE

1. WORK SHALL COMPLY WITH ALL APPLICABLE CODES.
2. AS BUILT DRAWINGS ALONG WITH ONE YEAR WARRANTY LETTER WILL BE FORWARDED TO THE APPROPRIATE PARTY UPON COMPLETION OF PROJECT.
3. 1" CONDUIT MUST BE PROVIDED AT ALL NAC PANELS.
4. MINIMUM OF 1/2" SLEEVE MUST BE PROVIDED FOR ALL RTU 2000 CFM OR GREATER.
5. ALL WAREHOUSE HORN-STROBES SHALL BE 30 FEET FROM FINISHED FLOOR.

[illegible]