

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240962
Address: 1925 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Wednesday, July 17, 2024

Corrective Action Required:

1	Miscellaneous Correction	1925 SW Merryman. Occupancy Remove dust covers from smoke detectors Front bathroom vent fan is not installed Master bathroom vent fan is not installed Fireplace is not installed Garage to house self closing door does not have its seal installed and could not be inspected Fire block all gaps in sheet rock in garage Garage attic access hatches are not installed Basement bathroom vent fan not installed Sod, sump pump extensions and splash pads are not installed Pay \$75 fee associated with this permit
---	--------------------------	---

Comments: