

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241617
Address: 1717 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, July 17, 2024

Corrective Action Required:

2	Miscellaneous Correction	1717 SW Hightown All rough (2) Fire block top of chase in bathroom 4 Fire block top of chase between garage and bathroom 4 Fire block top of chase in pantry Stud in utility room at plumbing waste line needs a stud shoe installed (nail all holes) Fire block at electrical in outside corner of primary bedroom Fire block hole above UFER in the basement
---	--------------------------	--

Comments: