

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241112

Address: 3731 SW KNOXVILLE CT, LEES SUMMIT, MO 64082  
3729 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Kyle Beard	Failed	Wednesday, July 17, 2024

Corrective Action Required:

1	Miscellaneous Correction	3729 and 3731. Rated assembly
		3729
		Fire block large gap at ridge
		3731
		Fire block large gap at ridge
		Fire decking joints that are larger than 1/4 of an inch wide needs to be fire sealed

Comments: