

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20234377
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection	Patrick Schonfeldt	Passed	Wednesday, July 17, 2024

Informational:

1	Misc	7-12-24 PS hydrant #056-065 relocated per plans for arboridge dr road widening
		7-15-24 PS Contractor poured concrete kicker and thrust block at tee and hydrant 056-065
		7-17-24 PS Contractor backfilled

Comments: