

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240545

Address: 3713 SW CLAYTON PL, LEES SUMMIT, MO 640823715 SW CLAYTON PL, LEES SUMMIT, MO
640823717 SW CLAYTON PL, LEES SUMMIT, MO 640823711 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Failed	Wednesday, July 17, 2024

Corrective Action Required:

1	Miscellaneous Correction	3717-3715-3713 & 3711 SW Clayton Rated assembly
		3717 -Provide caulking details for electrical service cable at rated basement wall -Roof vent cut out within 4 feet to rated assembly wall -Gap at the ridge is greater than 1/4 of an inch
		3715 -Provide caulking information at basement electrical service cable at rated assembly walls -Ridge in attic area has a greater than 1/4 of an inch gap in fire rated plywood along south side
		3713
		3711

Comments: