

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240545

Address: 3713 SW CLAYTON PL, LEES SUMMIT, MO 640823715 SW CLAYTON PL, LEES SUMMIT, MO
640823717 SW CLAYTON PL, LEES SUMMIT, MO 640823711 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, July 17, 2024

Corrective Action Required:

1	Miscellaneous Correction	3711-3713-3715 & 3717 SW Clayton All rough 3711 3713 3715 -2x10 floor joist have been notched within 2 inches of the bottom edge in the basement for electrical service cable Shawn Hoffman 07/17/2024 2:05 PM ENGINEERS CORRECTIONS NOT COMPLETED 3717 -Have approved fire caulking at electrical service cable between units
---	--------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: