

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240499  
Address: 2237 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Wednesday, July 17, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>-Approval from Fire and Planning dept</li><li>-Provide a permanent plaque showing the location of all the electrical services to the building</li><li>-Receptacle weatherproof cover at rear exit fell off</li><li>-Secure grounding electrode conductor raceways</li><li>-Secure AC whip within 12" of disconnect</li><li>-Fire caulk penetrations of fire-rated wall</li><li>-Install panel open breaker slot</li><li>-Door threshold shall not exceed 1/2". Threshold more than 1/4" shall be beveled</li><li>-Sprinkler head missing at west side of office</li><li>-EM light in women restroom not working properly</li><li>-Provide handle for accessible toilet stall</li><li>-Support bath fan duct</li></ul>
---	------	---

Comments: