

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20241128  
Address: 2229 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Wednesday, July 17, 2024

Corrective Action Required:

1	Misc	-License tax fee has not been paid -Fire and Planning approval required -Fire caulk penetrations of fire wall -Install breaker cover for rear panel -Label all breakers and panels; identify all circuits per NEC 210.5 -Door threshold shall not exceed 1/2". Threshold more than 1/4" shall be beveled -Operation of all doors cannot require twisting of the wrists
---	------	--

Comments: