

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243018
Address: 1905 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Kyle Beard	Passed	Thursday, July 18, 2024

Informational:

2	Miscellaneous Correction	Footing passed by third party. Exterior piers were not mentioned in footing report
---	-----------------------------	------------------------------------------------------------------------------------

Comments: