

July 9, 2024

City of Lee's Summit, MO  
ATTN: Gene Williams, P.E.  
220 SE Green  
Lee's Summit, MO 64063

**RE: PRSUBD20243187 – Revised Plans for Detention Basin at Discovery Park – The Village at Discovery Park**

Own, Inc. has received your comments dated July 5<sup>th</sup>, 2024 and has the following responses:

<b>Engineering Review-Grading</b>	Gene Williams, P.E.	Senior Staff Engineer	Corrections
-----------------------------------	---------------------	-----------------------	-------------

1. Please show a plan view of the grating on top of the outlet structure. It is difficult to determine what is being proposed without a plan view.  
OWN RESPONSE: Plan view added to sheet C202 – Spillway Details.
2. Would it be better to show a “raised” grating for the top of the outlet structure, or “domed” grating?  
OWN RESPONSE: Raised grate added to sheet C202 – Spillway Details.
3. The stormwater study dated June 2024 should be re-named to “Final Stormwater Study” or equivalent rather than “Preliminary.”  
OWN RESPONSE: Storm study title has been revised.

Please feel free to contact me with any additional questions or comments.

Sincerely,



Jeff Bartz, PE (OWN, Inc.)