



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113810, Building Permit - Commercial
Address: 117 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mike Copeland	Failed	Thursday, September 22, 2011

Corrective Action Required

1	P305 PROTECTION OF PIPES AND PLUMBING SYSTEM COMPONENTS	PROTECT HORZ. VENT PIPE THAT IS LESS THAN 2 INCHES FROM STUD FACE.
---	--	---

Comments: