

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20232768  
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Thursday, July 18, 2024

Corrective Action Required:

1	STAIR TOWER 1	-1st layer behind stringers only at floors 1-3 -2nd layer behind stringers at floors 1-2 ***not complete at truss space, ok for stringers
---	---------------	--

Corrective Action Required:

2	STAIR TOWER 2
---	---------------

Corrective Action Required:

3	STAIR TOWER 3
---	---------------

Corrective Action Required:

4	STAIR TOWER 4
---	---------------

Corrective Action Required:

5	STAIR TOWER 5
---	---------------

Corrective Action Required:

6	ELEVATOR 1	-1st layer, unit side behind trusses
---	------------	--------------------------------------

Corrective Action Required:

7	ELEVATOR 2
---	------------

**Comments:**