

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20234377
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Patrick Schonfeldt	Passed	Friday, July 19, 2024

Informational:
1 Misc 7-17-24 PS Bair performed proof roll on base road widening of arboridge dr. This included proof roll for curbs as well to match monolithic existing. Passed for surface

Comments: