

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242080

Address: 3725 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
3723 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Friday, July 19, 2024

Corrective Action Required:

1	Miscellaneous Correction	3723 -5/8 inch anchor bolts are not completed -Front porch soffit is covered without inspection for truss tie down screws
		3725 -Tension hold down straps are not nailed off -Front porch soffit is covered without inspection for truss tie down screws

Comments: