

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241344
Address: 840 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Friday, July 19, 2024

Informational:
1 Misc

OK to cover except as noted below:
-Mechanical room (open ceiling) PVC piping must comply with sec 602 of 2018 IMC
-123, 124-not done
-115-Seal penetrations in firewall
-Complete electrical and install cover plate at back wall

Comments: