

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235214
Address: 2971 SE SHENANDOAH PKWY, Unit:G3, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Shawn Hoffman	Partial	Friday, July 19, 2024

Informational:

1 Misc -Exterior wall grade beam-OK

Corrective Action Required:

2 Misc Unit G3 Building 1, 2 East side, South side and west side up to long straight stretch
Steel not connected on West side long stretch

Comments: