

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241184  
Address: 3208 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Alex Fischer	Failed	Friday, July 19, 2024

Informational:

1 Misc

Garage and covered front porch okay to cover

Corrective Action Required:

2 Misc

- Seal hole north wall of garage up in above ceiling/ attic space
- Missing fire blocking at top of chase to the left side of fireplace
- Missing fire blocking at top of chase in bedroom 5
- Triple truss girder in master closet does not appear to be nailed together on both sides
- Double truss girder between bedroom 2 and bathroom appears to have insufficient nails

Comments: