## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20226232

Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly Inspection Robb Popp Partial Friday, July 19, 2024

Informational:

1 FIRST FLOOR -Shaft layer, 1st and 2nd layer at 2nd floor separation in AHU 1E-233

-Shaft layer and 1st and 2nd layer at mech chase outside of AHU 1E-233

Corrective Action Required:

2 Misc 3e-322,323,264,264:

-COMPLETE SCREW PATTERN AND DRYWALL INSTALLATION, SEAL

**PENETRATIONS** 

Corrective Action Required:

3 SECOND FLOOR Corrective Action Required:

4 THIRD FLOOR -Shaft layer at 3E-303

**Comments:**