

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241195  
Address: 4359 NE HIDEAWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Monday, July 22, 2024

Corrective Action Required:

1	Misc	-Fb bedroom 4 closet walls and bathroom exterior wall from ceiling space; fb all basement wall from ceiling & joist space throughout
		-Over notched joist above bedroom 4 **Redo return air pan-off

**Comments:**