

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20234175  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Shawn Hoffman	Failed	Monday, July 22, 2024

Corrective Action Required:

1	Misc	- Upload Third Party footing inspection
		- Provide Simpson LST A30 straps @ each door from header to studs per plans
		-
		- Electrical no completed
		No electrical inspection done
		- panel not labeled

**Comments:**