

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234175
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Shawn Hoffman	Failed	Monday, July 22, 2024

Corrective Action Required:

1	Misc	- Upload Third Party footing inspection
		- Provide Simpson LST A30 straps @ each door from header to studs per plans
		-
		- Electrical no completed
		No electrical inspection done
		- panel not labeled

Comments: