



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20112915, Building Permit - Commercial  
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Commercial</b>	John Borns	Partial	Thursday, September 22, 2011

Partial Correction  
1 MISC

OK TO COVER WHEN READY 4" C.I. SANITARY SEWER SERVICE LINE FROM FCO @ (1)/(A.6) WEST TO M.H. LOCATION @ STA 0+07.95;

Partial Correction  
2 MISC

OK TO COVER WHEN READY 4" PVC SAN SEWER LINE FROM WEST BUILDING LINE TO STA 0+07.95; SAMPLING M.H. PER LS D&C MANUAL SS-6; 4" PVC FROM M.H. TO TAPPING SLEEVE AT SEWER SERVICE LINE PER APROVED DRWG

**Comments:**