

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241488
Address: 4516 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Kyle Beard	Failed	Monday, July 22, 2024

Corrective Action Required:

1	Miscellaneous Correction	Gas line pressure at 1:20 pm in the sun is only 1.5 psi Set pipe pressure at 10 psi and reschedule
---	--------------------------	---

Comments: