CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20235733Address:209 SE GREEN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspec	tion:	Inspector:	Outcome:	Date:
	slab Plumbing Inspection nercial	Robb Popp	Partial	Tuesday, July 23, 2024
Inform	ational:			
1	Misc A	Areas approved:		
	-	West bathroom group and mechanical room		
Correct	tive Action Required:			
2	Misc -	Provide clean out at exter	rior building sewer	

Comments: