

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242078  
Address: 2070 NW LOWENSTEIN DR, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Tuesday, July 23, 2024

Corrective Action Required:

1	Misc	Partial only
		*Hard lids approved
		-REMOVE SCREWS AND SEAL PENETRATIONS IN DRYER DUCT

**Comments:**