

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242078  
Address: 2070 NW LOWENSTEIN DR, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector: | Outcome: | Date:                  |
|---------------------------------|------------|----------|------------------------|
| <b>Above Ceiling Inspection</b> | Robb Popp  | Partial  | Tuesday, July 23, 2024 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | Partial only                                       |
|   |      | *Hard lids approved                                |
|   |      | -REMOVE SCREWS AND SEAL PENETRATIONS IN DRYER DUCT |
|   |      | -SEAL FIREWALL PENETRATION AT LOBBY                |

**Comments:**