

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242357
Address: 3212 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, July 23, 2024

Informational:

1	Misc	Garage portal frame inspected only okay to cover
---	------	--

Corrective Action Required:

2	Misc	-no plans on site to check covered front porch -trusses on front porch missing hold downs
---	------	--

Comments: