



## **FIRE DEPARTMENT**

**Prevention Division  
(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20240118	Date:	July 22, 2024
Project Title:	JOHN KNOX VILLAGE - COURTYARDS BUILDING E	Applicant:	
Location:	515 NW MOORE ST, LEES SUMMIT, MO 64081		ALL SAFE FIRE PROTECTION LLC 6603 ROYAL ST STE D PLEASANT VALLEY, MO 64068
Type of Work:			
Occupancy Group:	R-2	Primary:	(816) 492-7202
Description:	JOHN KNOX VILLAGE - COURTYARDS BUILDING E - SENIOR LIVING INDEPENDENT LIVING APARTMENTS		
Construction Type:	Type VA (1 hour)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Craig Hill**

**Rejected**

1. Sheet 1 shows Fire Dept Conn as a "4"OUT TO "4x2½ x 2½". This need to be a 4" storz with a 30 degree elbow.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**