

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235933
Address: 1059 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Tuesday, July 23, 2024

Corrective Action Required:

1	Misc	- uncover man hole at back of house - complete final grading and sod - Extend sump discharge 36" away from foundation - provide splash pads at downspouts to move water 36" away from foundation Land sewer trace wire to grade
---	------	---

Comments: