

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240545
Address: 3713 SW CLAYTON PL, LEES SUMMIT, MO 640823715 SW CLAYTON PL, LEES SUMMIT, MO
640823717 SW CLAYTON PL, LEES SUMMIT, MO 640823711 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Tuesday, July 23, 2024

Corrective Action Required:

2	Miscellaneous Correction	3715
---	--------------------------	------

-2x10 floor joist have been notched within 2 inches of the bottom edge in the basement for electrical service cable
ENGINEERS CORRECTIONS NOT COMPLETED

Still need to install CS-16 metal strap per engineers letter (#2 a)

Re inspection at 8:35 am showed no improvement has been observed
07/23/24. KBEARD

Comments: