

## FIRE DEPARTMENT

## Prevention Division (816)969-1300

## **PLANS REVIEW CONDITIONS**

FIRE & SECURITY SOLUTIONS GROUP INC

11240 STRANG LINE RD

LENEXA, KS 66215-4039

Primary: (913) 789-7160

Permit No: PRCOM20231975 Date: July 23, 2024

Project Title: TAILORMADE LANDING - FIELD HOUSE Applicant:

Location:

1550 SE HAMBLEN RD, LEES SUMMIT, MO 64081

Type of Work:

Occupancy Group: A-4

Description: TAILORMADE LANDING - FIELD

HOUSE - NEW SINGLE STORY BUILDING WITH

MEZZANINE HOUSING AN ATHELTIC CLUB FOR SPORTS

TRAINING AND GAMES

Construction Type: Type IIB (Unprotected)

Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review Reviewed By: Craig Hill Rejected

1. Action Required: Change the notification in rooms 121, 119, 126, and 128 to a strobe light only.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.