

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Failed	Tuesday, July 23, 2024

Informational:

1	FIRST FLOOR	-Shaft layer, 1st and 2nd layer at 2nd floor separation in AHU 1E-233 -Shaft layer and 1st and 2nd layer at mech chase outside of AHU 1E-233
---	-------------	---

Corrective Action Required:

2	Misc	3e-322,323,264,264: -COMPLETE SCREW PATTERN AND DRYWALL INSTALLATION, SEAL PENETRATIONS
---	------	--

Corrective Action Required:

3	SECOND FLOOR
---	--------------

Corrective Action Required:

4	THIRD FLOOR	-Shaft layer at 3E-303
---	-------------	------------------------

**Comments:**