

## 24-007756-02 LOC

**Date:** 5/9/2024 **Time:** 01:47 PM

**Page:** 1 of 2

## **Letter of Certification**

Contact: Project: LSMO Water Utilites

Name: MAR Building Solutions Builder PO#:

Address: 1305 Jefferson Street Jobsite: 123456 Hamblen

City, State: Lees Summit, Missouri 64081 City, State: Lees Summit, Missouri 64002 Country: United States County, Country: Jackson, United States

This is to certify that the above referenced project has been designed in accordance with the applicable portions of the Building Code specified below. All loading and building design criteria shown below have been specified by contract and applied in accordance with the building code.

**Overall Building Description** 

| Shape                      | Overall  | Overall      | Floor Area | Wall Area | Roof Area | Max. Eave | Min. Eave | Max. Roof  | Min. Roof | Peak   |
|----------------------------|----------|--------------|------------|-----------|-----------|-----------|-----------|------------|-----------|--------|
|                            | Width    | Length       | (sq. ft.)  | (sq. ft.) | (sq. ft.) | Height    | Height 2  | Pitch      | Pitch     | Height |
| Covered Parking Addition   | 60/0/0   | 64/0/0       | 3840       | 3619      | 3843      | 20/6/0    | 18/0/0    |            |           |        |
|                            |          |              |            |           |           |           |           | -0.5000:12 |           |        |
| Covered Parking (Existing) | 60/0/0   | 190/0/0      | 11400      | 1078      | 11410     | 20/6/0    | 18/0/0    | 0.5000:12  |           |        |
|                            | Total Fo | r All Shapes | 15240      | 4697      | 15253     |           |           |            |           |        |

Loads and Codes - Shape: Covered Parking Addition

Country: United States City: Lees Summit County: Jackson State: Missouri Building Code: 2018 International Building Code Structural: 16AISC - ASD Rainfall: I: 7.00 inches per hour Building Risk/Occupancy Category: II (Standard Occupancy Structure) Cold Form: 16AISI - ASD f'c: 3000.00 psi Concrete

**Dead and Collateral Loads** Roof Live Load Roof Covering + Second. Dead Load: Varies Collateral Gravity: 10.00 psf

Frame Weight (assumed for seismic):2.50 psf

Wind Load

Collateral Uplift: 0.00 psf

Wind Speed: Vult: 115.00 (Vasd: 89.08) mph

The 'Envelope Procedure' is Used Primaries Wind Exposure: C - Kz: 0.882 Parts Wind Exposure Factor: 0.882 Wind Enclosure: Partially Open Topographic Factor: Kzt: 1.0000

Ground Elevation Factor: Ke: 0.9636 NOT Windborne Debris Region

Base Elevation: 0/0/0 Site Elevation: 1024.0 ft Primary Zone Strip Width: 2a: 12/0/0 Parts / Portions Zone Strip Width:

> Walls, a: 6/0/0 Roof(s), 0.6h: 10/9/10

Velocity Pressure: qz: 24.46, (C&C) 24.46 psf

Snow Load

Ground Snow Load: pg: 20.00 psf

Flat Roof Snow: pf: 16.80 psf Design Snow (Sloped): ps: 16.80 psf

Rain Surcharge: 0.00 psf

Specified Minimum Roof Snow: 20.00 psf (Code) Exposure Factor: 2 Partially Exposed - Ce: 1.00

Snow Importance: Is: 1.000 Thermal Factor: Unheated - Ct: 1.20 Ground / Roof Conversion: 0.70 Obstructed or Not Slippery

Roof Live Load: 20.00 psf Not Reducible

Seismic Load

Lateral Force Resisting Systems using Equivalent

Force Procedure

Mapped MCE Acceleration: Ss: 12.00 %g Mapped MCE Acceleration: S1: 7.00 %g Site Class: Stiff soil (D) - Default

Seismic Importance: Ie: 1.000 Design Acceleration Parameter: Sds: 0.1280

Design Acceleration Parameter: Sd1: 0.1120 Seismic Design Category:: B

Seismic Snow Load: 0.00 psf % Snow Used in Seismic: 0.00 Diaphragm Condition: Flexible

Fundamental Period Height Used: 19/3/0

Transverse Direction Parameters System NOT detailed for Seismic Redundancy Factor: Rho: 1.00 Fundamental Period: Ta: 0.2983 R-Factor: 3.00

Overstrength Factor: Omega: 2.50 Deflection Amplification Factor: Cd: 3.00

Base Shear: V: 0.0427 x W

Longitudinal Direction Parameters System NOT detailed for Seismic Redundancy Factor: Rho: 1.00 Fundamental Period: Ta: 0.1838 R-Factor: 3.00 Overstrength Factor: Omega: 2.50

Deflection Amplification Factor: Cd: 3.00

Base Shear: V: 0.0427 x W

Version: 24.1.1

Pricing: 24.1.1

Loads and Codes - Shape: Covered Parking Shape Covered Parking is set as an existing shape.



## 24-007756-02 LOC

**Date:** 5/9/2024 Time: 01:47 PM Page: 2 of 2

Building design loads and governing building code is provided by the Builder and is not validated by Butler Manufacturing, a division of BlueScope Buildings North America, Inc. The Builder is responsible for contacting the local Building Official or project Design Professional to obtain all code and loading information for this specific building site.

The design of this building is in accordance with Butler Manufacturing, a division of BlueScope Buildings North America, Inc. design practices which have been established based upon pertinent procedures and recommendations of the Standards listed in the Building Code or later editions.

This certification DOES NOT apply to the design of the foundation or other on-site structures or components not supplied by Butler Manufacturing, a division of BlueScope Buildings North America, Inc., nor does it apply to unauthorized modifications to building components. Furthermore, it is understood that certification is based upon the premise that all components will be erected or constructed in strict compliance with pertinent documents for this project. Butler Manufacturing, a division of BlueScope Buildings North America, Inc. DOES NOT provide general review of erection during or after building construction unless specifically agreed to in the contract documents.

The undersigned engineer in responsible charge certifies that this building has been designed in accordance with the contract documents as indicated in this

| Engineer in responsible charge | Date: | Engineer's Seal: |
|--------------------------------|-------|------------------|



05/09/2024

Version: 24.1.1

Pricing: 24.1.1