

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240888
Address: 1833 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|------------|----------|--------------------------|
| Erosion Control | Kyle Beard | Failed | Wednesday, July 24, 2024 |

Corrective Action Required:
2 DCM3 ESC
REQUIRED 2 DAY

EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.

Silt fence has been removed from the front of the property.
Remove gravel from street

Full erosion control measures are required and must be maintained until CofO

Comments: