

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241112

Address: 3731 SW KNOXVILLE CT, LEES SUMMIT, MO 640823729 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Wednesday, July 24, 2024

Corrective Action Required:

2	Miscellaneous Correction	3729 and 3731. Rated assembly
		3729 Passed
		3731 Fire decking joints that are larger than 1/4 of an inch wide needs to be fire sealed

Comments: