

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20241670, Public Works Right of Way Permit
Address: 1928 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Partial	Wednesday, July 24, 2024

Corrective Action Required

1 Misc

Site Visit - The crew was boring when I arrived. I spoke with the crew and they said they had already hit 20ft and are aware of the 18ft minimum needed.

Comments: