

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240573

Address: 3737 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
3735 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Wednesday, July 24, 2024

Corrective Action Required:

2	Miscellaneous Correction	Both units sod, splash pads and sump pump extensions are not installed Deck is missing a joist hanger Deck joist hanger is missing nails
---	--------------------------	---

Final grading needs to be completed before plot plan inspection can be conducted

Pay \$75 fee associated with this permit

TCO passed for both units

Comments: