CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20240569Address:2755 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	in:	Inspector:	Outcome:	Date:
All Rough Resident	n Inspection - ial	Mitchell Schwarz	Failed	Wednesday, July 24, 2024
Corrective Action Required: 3 Misc		Missing double Lvl above living room.		
		Okay to insulate		

Comments: