

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Failed	Wednesday, July 24, 2024

Corrective Action Required:

1	Misc	-Pre final inspection for 1st floor addition: -Complete Above Ceiling inspection items -Complete rated assembly at Soil room and mechanical room -All toilets to be 16-18" from side wall -All sinks to be max 34" to top of sink -Unable to test GFCIs throughout -Install all plumbing protection at sinks -Sidewall grab bars to be spaced max 12" from back wall -Install backwall grab bars per plan -Open all electrical panels for inspection, label all panels *Not a complete inspection
---	------	---

Comments: