

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

July 24, 2024

ACI BOLAND ARCHITECTS 1710 WYANDOTTE ST KANSAS CITY, MO 64108

Permit No: PRCOM20243580

Project Title: SAINT LUKES EAST - DIALYSYS CLINIC STORAGE CLOSET Project Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

Parcel Number: 52440044000000000

Location / Legal SAINT LUKES HOSPITAL OF LEES SUMMIT LOTS 1 & 2---LOT 1

Description:

Type of Work: ALTERATION COMMERCIAL

Occupancy Group: INSTITUTIONAL, SUPERVISED ENVIRONMENT

Description: SAINT LUKES EAST - ALTERATION OF EXISTING DIALYSIS CLINIC WAITING ROOM TO CREATE

STORAGE CLOSET

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire Department (816) 969-1300

Licensed Contractors Reviewed By: Joe Frogge Rejected

1. Lee's Summit Code of Ordinance, Section7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the company name of the licensed general contractor and the name, email address & phone number for the on-site contact.

2. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

Building Plan Review Reviewed By: Joe Frogge Rejected

1. Provide details for construction at FEC in rated wall.



DEVELOPMENT SERVICES

Fire Plan Review Reviewed By: Craig Hill Approved with Conditions

- 1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.
- 2. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.