

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20230660  
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Dustin Agcopra	Partial	Thursday, July 25, 2024

Informational:

1 Misc

6-19-24 BR Contractor (JE Dunn) saw cut sidewalk on south entrance which are joint to joint and the north entrance sidewalk there are cut at joint to joint.

7-25-24 Dustin A, public SW on south entrance is formed and compacted. Slopes are in compliance. Informed contractor of white cure needed on public SW and to not apply picture frame on new SW . The existing Sw does have picture frame but will prob be replaced down the road . Approved to pour.

**Comments:**