

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242441
Address: 1220 NW MAIN ST, Unit:E, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Partial	Thursday, July 25, 2024

Corrective Action Required:

1 Misc

Inspection for demising wall only:

- Complete framing at return wall and pass through
- Update and submit plan to show new demising wall labeled as existing on plans and provide UL details for firewall

*OK TO START 1 SIDE ROCK

Comments: