

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235206
Address: 2971 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Concrete Walls and Columns Inspection	Khanh Nguyen	Partial	Thursday, July 25, 2024

Corrective Action Required:

1	Misc	Foundation wall OK: -G/4 to A/4
---	------	------------------------------------

****Install electrical service grounding electrode conductor at north end of building. Call for inspection before pouring**

Comments: