

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235206  
Address: 2971 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Concrete Walls and Columns Inspection</b>	Khanh Nguyen	Partial	Friday, July 26, 2024

Corrective Action Required:

1	Misc	Foundation wall OK: -G/4 to A/4
---	------	------------------------------------

**Comments:**