

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20236522
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-----------------------|
| Piers/Caissons Inspection - Commercial | Robb Popp | Failed | Friday, July 26, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | Provide pier detail for inspection -Ground rod and conductor not installed |
|---|------|---|

Comments: