

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241190
Address: 2134 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Friday, July 26, 2024

Partial Correction:

1	Miscellaneous Correction	2134 SW Rutherford. All rough (2) -Stair platform going to the basement from the main entry is not supported at the S/E corner (2x4 vertical brace installed is non treated lumber in contact with cement)
---	--------------------------	---

Comments: