

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232726
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------|-------------|----------|-----------------------|
| Pavement-Surface | Devon Perry | Partial | Friday, July 26, 2024 |

| | |
|----------------|--|
| Informational: | |
| 1 Misc | 7-26-24 DP. ESS is onsite pouring the north turn lane off Douglas. They poured with KCMMB 4K concrete, 10" thick. Broom finish and white cure. |

Comments: