

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20230994  
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Bobby Richest	Partial	Friday, July 26, 2024

Informational:  
1 Misc

5-14-24 BR Erosion control is up and working order

5-23-24 BR Grass needs to be trim down so that public fire hydrant is visible and silt fence is visible and work properly. Also need to use approve gutter buddy's on erosion control plans for inlet protection.

5-29-24 BR Erosion control is up and working order. Grass is trim down and public fire hydrant is visible.

6-4-24 BR Erosion control is up and working order.

6-11-24 BR Erosion control is up and working order.

6-17-24 BR Erosion control is up and working order.

6-26-24 BR Erosion control is up and working order.

7-3-24 BR Erosion control is up and working order.

7-10-24 Erosion control is up and working order.

7-17-24 BR Erosion control is up and working order.

7-26-24 BR Erosion control is up and working order.

**Comments:**